

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7770-1440:100 Page 1 of 1

**CATEGORY:** Valves/Switches

**LISTEE:** Kennedy Valve, 1021 East Water Street, Elmira, NY 14901  
Contact: \*John A. Chalk (607) 734-2211 Fax (800) 952-4771

**DESIGN:** Models 93G1 grooved-end and 93W wafer end butterfly valves in the 2-1/2", 3", 4", 6" and 8" sizes. These valves may employ internal supervisory tamper switches. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Working pressure: 175 psi

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, and UL label.

**APPROVAL:** Listed as butterfly valves for use as a water supply control valve for fire protection systems.  
Suitable for indoor/outdoor use.

\*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 5, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager